

## § 95.17–90

other than tanks, at least 2 fire hydrants, in addition to those required for the machinery space by Subpart 95.10, shall be installed outside of the machinery space entrance. Such hydrants shall be fitted with sufficient hose so that any part of the machinery space may be reached with at least 2 streams of water, and each hose shall be equipped with an approved combination nozzle, applicator, and self-cleaning strainer as described in § 95.10–10(i)(3).

### § 95.17–90 Installations contracted for prior to November 19, 1952.

(a) Installations contracted for prior to November 19, 1952, shall meet the following requirements:

(1) Existing arrangements, materials, and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original installation.

(2) The details of the systems shall be in general agreement with §§ 95.17–5 through 95.17–20, with the exception of § 95.17–5(a)(2), insofar as is reasonable and practicable. A 6-inch blanket of foam in 5 minutes for tanks and 3 minutes for other spaces will be considered as meeting the requirements of § 95.17–5.

## Subpart 95.30—Automatic Sprinkler Systems, Details

### § 95.30–1 Application.

Automatic sprinkler systems shall comply with NFPA 13–1996.

[CGD 95–028, 62 FR 51207, Sept. 30, 1997]

## Subpart 95.50—Hand Portable Fire Extinguishers and Semiportable Fire Extinguishing Systems, Arrangements and Details

### § 95.50–1 Application.

(a) The provisions of this subpart, with the exception of § 95.50–90, shall apply to all vessels, other than unmanned barges and fishing vessels, con-

## 46 CFR Ch. I (10–1–11 Edition)

tracted for on or after November 19, 1952. Such vessels contracted for prior to November 19, 1952, shall meet the requirements of § 95.50–90.

### § 95.50–5 Classification.

(a) Hand portable fire extinguishers and semiportable fire extinguishing systems shall be classified by a combination letter and number symbol. The letter indicating the type of fire which the unit could be expected to extinguish, and the number indicating the relative size of the unit.

(b) The types of fire will be designated as follows:

(1) “A” for fires in ordinary combustible materials where the quenching and cooling effects of quantities of water, or solutions containing large percentages of water, are of first importance.

(2) “B” for fires in flammable liquids, greases, etc., where a blanketing effect is essential.

(3) “C” for fires in electrical equipment where the use of nonconducting extinguishing agent is of first importance.

(c) The number designations for size will start with “I” for the smallest to “V” for the largest. Sizes I and II are considered hand portable fire extinguishers and sizes III, IV, and V are considered semiportable fire extinguishing systems which shall be fitted with suitable hose and nozzle or other practicable means so that all portions of the space concerned may be covered. Examples of size graduations for some of the typical hand portable and semiportable fire extinguishing systems are set forth in Table 95.50–5(c).

TABLE 95.50–5(c)

Classification		Soda-acid and water, gallons	Foam, gallons	Carbon dioxide, pounds	Dry chemical, pounds
Type	Size				
A .....	II .....	2½	2½	.....	.....
B .....	I .....	.....	1¼	4	2
B .....	II .....	.....	2½	15	10
B .....	III .....	.....	12	35	20
B .....	IV .....	.....	20	50	30
B .....	V .....	.....	40	100	50
C .....	I .....	.....	.....	4	2
C .....	II .....	.....	.....	15	10

## Coast Guard, DHS

## § 95.50–10

(d) All hand portable fire extinguishers and semiportable fire extinguishing systems shall have permanently attached thereto a metallic name plate giving the name of the item, the rated capacity in gallons, quarts, or pounds, the name and address of the person or firm for whom approved, and the identifying mark of the actual manufacturer.

(e) Vaporizing-liquid type fire extinguishers containing carbon tetrachloride or chlorobromomethane or other toxic vaporizing liquids shall be removed from all vessels.

## § 95.50–10 Location.

(a) Approved hand portable fire extinguishers and semiportable fire extinguishing systems shall be installed in accordance with Table 95.50–10(a). The location of the equipment shall be to the satisfaction of the Officer in Charge, Marine Inspection. Nothing in this paragraph shall be construed as limiting the Officer in Charge, Marine Inspection, from requiring such additional equipment as he deems necessary for the proper protection of the vessel.

TABLE 95.50–10(a)—HAND PORTABLE FIRE EXTINGUISHER AND SEMI-PORTABLE FIRE-EXTINGUISHING SYSTEMS

Space	Classification (see § 95.50–5)	Quantity and location
<i>Safety areas<sup>1</sup></i>		
Wheelhouse or fire control room .....	.....	None required.
Stairway and elevator enclosures .....	.....	Do.
Communicating corridors .....	A-II .....	1 in each main corridor not more than 150 feet apart. (May be located in stairways.)
Lifeboat embarkation and lowering stations .....	.....	None required.
Radio room.	.....	.....
C-1 <sup>2</sup> .....	2 in vicinity of exit. <sup>2</sup>	.....
<i>Accommodations<sup>1</sup></i>		
Staterooms, toilet spaces, public spaces, offices, lockers, isolated storerooms, and pantries, open decks, etc.	.....	None required.
<i>Service spaces<sup>1</sup></i>		
Galleys .....	B-II or C-II .....	1 for each 2,500 square feet or fraction thereof suitable for hazards involved.
Paint and lamp rooms .....	B-II .....	1 outside space in vicinity of exit.
Accessible baggage, mail, and specie rooms, and storerooms ..	A-II .....	1 for each 2,500 square feet or fraction thereof located in vicinity of exits, either inside or outside the spaces.
Carpenter shop and similar spaces .....	A-II .....	1 outside the space in vicinity of exit.
<i>Machinery spaces</i>		
Coal-fired boilers: Bunker and boiler space .....	.....	None required.
Oil-fired boilers: Spaces containing oil-fired boilers, either main or auxiliary, or their fuel-oil units.	B-II; B-V .....	2 required <sup>3</sup> ; 1 required. <sup>4</sup>
Internal combustion or gas turbine propelling machinery spaces	B-II .....	1 for each 1,000 brake horsepower, but not less than 2 nor more than 6. <sup>5</sup>
.....	B-III .....	1 required. <sup>6,7</sup>
Electric propulsive motors or generators of open type .....	C-II .....	1 for each propulsion motor or generator unit.
Enclosed ventilating systems for motors and generators of electric propelling machinery.	.....	None required.
<i>Auxiliary spaces:</i>		
Internal combustion or gas turbine .....	B-II .....	1 outside the space in vicinity of exit. <sup>7</sup>
Electric emergency motors or generators .....	C-II .....	1 outside the space in vicinity of exit. <sup>8</sup>
Steam .....	.....	None required.
Trunks to machinery spaces .....	.....	Do.
Fuel tanks .....	.....	Do.
<i>Cargo spaces</i>		
Inaccessible during voyage, including trunks and cargo tanks .....	.....	Do.
Accessible during voyage .....	.....	Do.

<sup>1</sup>For motorboats, the total number of hand portable fire extinguishers required for safety areas, accommodation spaces, and service spaces shall be 1 B-II for motorboats of less than 50 gross tons and 2 B-II for motor boats of 50 gross tons and over. Two B-I hand portable fire extinguishers may be substituted for 1 B-II.

<sup>2</sup>For vessels on an international voyage, substitute 1 C-II in vicinity of exit.

<sup>3</sup>Vessels of less than 1,000 gross tons require 1.

<sup>4</sup>Vessels of less than 1,000 gross tons may substitute 1 B-IV.

<sup>5</sup>Only 1 required for motorboats.

<sup>6</sup>If oil burning donkey boiler fitted in space, the B-V previously required for the protection of the boiler may be substituted. Not required where a fixed carbon dioxide system is installed.

<sup>7</sup>Not required on vessels of less than 300 gross tons if fuel has a flashpoint higher than 110 °F.